

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110 001


No. F6/DFS/MS/School/SZ/2022 / 257

Dated: 10/03/2022

FIRE SAFETY CERTIFICATE

Certified that the St. Michael's Sr. Sec. School, No. 3, Pusa Road, New Delhi-110005, comprises of ground plus two upper floors, owned/occupied by St. Michael's Sr. Sec. School was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/School/SZ/2019/682, dated 02-04-2019. The premises was re-inspected by the officer concerned of this department on 04-03-2022 in the presence of Fr. Jas Elanjikal, Principal of the school and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class B 'Educational Building' with effect from 10/03/2022 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions mentioned below.

Issued on 10 .03.2022 at New Delhi by


(Sunil Choudhary)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Principal, St. Michael's Sr. Sec. School, No. 3, Pusa Road, New Delhi-110005.
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi-54.

Conditions for the validity of fire safety certificate

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner/occupier shall apply for renewal of this FSC to Director in Form 'J' [Sub Rule (1) of Rule 37] alongwith a copy of this certificate, six month prior to its expiry.


ADV. FR. JAS ELANJIKAL
PRINCIPAL
ST. MICHAEL'S SR. SEC. SCHOOL
3, PUSA ROAD, KAROL BAGH
NEW DELHI-110005


Manager
St. Michael's Sr. Sec. School
3, Pusa Road, New Delhi-110005