




**DELHI JAL BOARD: GNCTD  
ZONAL LABORATORY WTP WAZIRABAD, DELHI-54**



**TEST REPORT**

Sample ID	Ref.No. D.J.B DTQC/WZD/2023/Paid-232-233		
Location /Address of Sample	ST. MICHAEL'S SENIOR SECONDARY SCHOOL, 3-Pusa Road, New Delhi-5.		
Letter Reference No.	SMS/DJB/1491/24	Ref. Letter Date	27.01.2024
Challan No.	423	Challan Date	30.01.2024
Sample Collection date	31.01.2024	Analysis Start date	31.01.2024
Any other Information	--	Analysis End date	02.02.2024
		Reporting date	02.02.2024

**TEST RESULTS**

S.N.	Parameters	Unit	As per the IS 10500		Results	
			Desirable limit	Permissible limit	Inlet	Outlet
1	Colour	Pt-Co	5	15	2.0	1.0
2	Odour	Agreeable	Agreeable	Agreeable	Agreeable	Agreeable
3	Turbidity	NTU	1	5	2.1	1.0
4	pH Value	--	6.5-8.5	No relaxation	7.31	7.45
5	Electrical Conductivity	µS/cm	-	-	472	84
6	Total Dissolved Solids	mg/L	500	2000	307	55
7	Total Alkalinity	mg/L	200	600	118	16
8	Total Hardness	mg/L	200	600	168	28
9	Calcium as Ca	mg/L	75	200	43.2	7.2
10	Magnesium as Mg	mg/L	30	100	14.4	2.8
11	Iron	mg/L	--	0.3	0.08	0.02
12	Chloride	mg/L	250	1000	47	13
13	Fluoride	mg/L	1.0	1.5	0.38	0.12
14	Ammonical-Nitrogen	mg/L	NIL	0.5	BDL	BDL
15	Nitrate	mg/L	--	45	8.8	1.4
16	Sulphate	mg/L	200	400	22	6.0
17	Residual Chlorine	mg/L	0.2	1.0	1.0	BDL
18	Coliform Count at 37°C	MPN/100 mL	Absent	--	0	0

\*BDL=Below Detection Limit

.....End of Report.....

**Remarks: For the tested parameters water samples conform IS-10500 & can be considered for the drinking purpose.**

Tested by  
Lab. Tech.

Verified by  
Asstt. Chemist

Authorized by Analyst  
Chemist (ACWA of Delhi)  
Water Works, Wazirabad  
Manager

**ADV. FR. JAS ELANJIKAL  
PRINCIPAL  
ST. MICHAEL'S SR. SEC. SCHOOL  
3 PUSA ROAD, KAROL BAGH**

St. Michael's Sr. Sec. School  
3, Pusa Road, New Delhi-110005

**MUNICIPAL CORPORATION OF DELHI**  
**(Office of the Deputy Health Officer)**  
**Public Health Department: Karol Bagh Zone**  
**Anand Parbat, New Delhi – 110005**  
**E-mail ID No. dhokbz@gmail.com**

No. DHO/KBZ/2023/ 33

Dated: 17.8.2023

**School Health Certificate**

To

The Principal  
St. Michael's Sr. Sec. School  
3, Pusa Road,  
New Delhi- 110005

Shift: Morning

Timing 07:30 am to 01:50 pm

No. of Students: Total - 1188

Boys 721

Girls 461

No. of Staff Members Working in School

Male 21

Female 45

1. That the accommodation provided for in class rooms as calculated.  
- Floor space in the class room is sufficient.
2. That the all rooms are well ventilated white washed and well lighted.
3. That the class rooms are kept neat and clean.
4. That the building, class rooms are in good condition.
5. That the drinking water is wholesome.
6. That the first aid box is also arranged in proper manner.
7. That the latrine arrangement is flush.
8. The no. of Toilet for Boys 22
9. The no. of Toilet for Girls 28
10. The no. of staff washroom 07
11. The premises found fit having no objection from Health point of view.


Validity : This Certificate is valid for One year from the date of issue.



**ADV. FR. JAS ELANJIKAL**  
**PRINCIPAL**  
**ST. MICHAEL'S SR. SEC. SCHOOL**  
**3, PUSA ROAD, KAROL BAGH**  
**NEW DELHI-110005**



**Manager**  
**St. Michael's Sr. Sec. School**  
**3, Pusa Road, New Delhi-110005**



**Deputy Health Officer**  
**Karol Bagh Zone**